



January 18, 2006

To: PROSPECTIVE PROPOSERS AND ALL OTHERS CONCERNED

From: Timothy Jecks, Contracts Analyst

Subject: BD-0409-06/TRJ – Mezzanine at the Fire Training Center

REVISED Due Date: **Cancelled**

ADDENDUM #3

Total pages: 1

The information included in this Addendum revises, clarifies, or supplements the specifications and other provisions of the contract documents and is considered part and parcel to the RFP/BID Package.

Purchasing and Contracts is cancelling BD-0409-06/TRJ and will require that a formal CC replace it due to additional information on the construction of the Mezzanine for the Fire Training Center. According to Section 502 of the Florida Building Code, the floor area of a 'mezzanine' can not be more than one-third of the area of the room or space in which the level is located. The proposed storage area will probably be classified as a 'story' since it covers over three-fourths of the room (3,250 sq. ft. level in a 4,200 sq. ft. room).

The county will obtain A&E documents of the building and will package them with the scope to create a new CC solicitation. All interested vendors are encouraged to check our website periodically for the new advertisement.

Failure to acknowledge receipt of this addendum on the submittal may result in disqualification of your bid response.

Signature on File

Timothy R. Jecks
Contracts Analyst