

DEPARTMENT OF FISCAL SERVICES

PURCHASING DIVISION



April 27, 2004

To: PROSPECTIVE PROPOSERS AND ALL OTHERS CONCERNED

From: Jacqui Perry, CPPB, Senior Procurement Analyst

Subject: BD-2000-04/JVP – **Furnish and Install Generators**

REVISED DUE DATE: May 11, 2004 at 2:00 P.M. Eastern time

ADDENDUM NO. 1

Total pages: 1

The information included in this Addendum revises, clarifies, or supplements the specifications and other provisions of the contract documents and is considered part and parcel to the RFP Package.

1. The following addenda adds: a site visit on May 4, 2004 10:00 am-12:00 pm. You will meet at Fire Station 12 at 325 Douglas Ave., Altamonte Springs, FL at 10:00 AM and you will need to sign in at that time, after that inspection we will proceed to Fire Station 14 at 600 Hattaway Dr., Altamonte Springs, FL.

2. The Following are answers to questions received:

2.1: *Who will supply the signed and sealed drawings for electrical and concrete to permit the projects? The concrete slab is in place.*

Answer: The contractor will provide the signed and sealed drawings for the electrical.

2.2: *Will the contractor pay for the engineered drawings?*

Answer: Yes

a) 2.3: *Scope 1-D- No drawings are available. Page 32-Item 1 D-*

Delete: The entire system shall be installed as shown on the plans, drawings, and specifications herein.

2.4: *Will permitting fees be waived?*

Answer: No

2.5: *Who will drain and remove existing unit?*

Answer: Current generator is propane (No draining required). The supplier or suppliers' contractor will be responsible for all unloading of new generator, setting the generator in the agreed location and will set the current generator in the parking lot or vehicle provided by the county. The new generator will be placed on the same concrete pad.

2.6: *Will all work be performed from 7am to 3:30pm?*

Answer: Work to be performed during normal work hours but starting no earlier than 7:00 AM. Check with City of Altamonte Springs for city codes that may apply.

3. *The bid date has been changed from 5/5/04 to 5/11/04 by 2:00 p.m.*

Failure to comply with this requirement will result in disqualification of your submittal.

Signature on File

Jacqui Perry, CPPB
Sr. Procurement Analyst