

DEPARTMENT OF FISCAL SERVICES

PURCHASING DIVISION



May 17, 2004

To: PROSPECTIVE PROPOSERS AND ALL OTHERS CONCERNED

From: Jacqui Perry, CPPB, Senior Procurement Analyst

Subject: BD-2000-04/JVP – **Furnish and Install Generators**

**REVISED DUE DATE:** May 25, 2004 at 2:00 P.M. Eastern time

**ADDENDUM NO. 3**

**Total pages: 1**

***The information included in this Addendum revises, clarifies, or supplements the specifications and other provisions of the contract documents and is considered part and parcel to the RFP Package.***

**The following addendum answers various questions submitted.**

1. Seminole County specifies a two (2) year basic warranty on 16231-4,a and will make no changes to it, unless the manufacturer standard warranty exceeds this time frame.
2. Seminole County specifies in 16231-5,a, a Detroit Diesel unit, however, any unit meeting the specification or exceeding it is acceptable.
3. 16231-6,a- also refers to Detroit Diesel, however, any unit meeting the specification or exceeding it is acceptable.
4. Specification 16231-6,a,1-Specifies a mechanical governor- Seminole County will consider all units as long as they meet or exceed specifications.
5. **Q:** Please clarify; is it the intent for the ATS to be networked to a remote computer or to have capability to be if desired in the future?  
**A:** No
6. **Q:** I would like for you to clarify the voltage and phase of the fire station # 12. The specs call for a three phase unit but I noticed that the site was single phase.  
**A:** 120/240 volts, 1 phase, 3 wire, 60 hertz
7. **Q:** At Fire Station # 14 that there was a children playground next door and that you should consider having the muffler mounted inside so that it is not a safety concern.  
**A:** Comply with applicable codes.
8. **Q:** Vendor stated that he did not think that piping would need to extend above roof.  
**A:** Comply with applicable codes.

Please note that no other questions can be submitted. If you are bidding other than what is specified you must include product literature, etc for review and the item must meet or exceed specification.

**Signature on File**

---

**Jacqui Perry, CPPB  
Sr. Procurement Analyst**