

DEPARTMENT OF FISCAL SERVICES

PURCHASING DIVISION



December 6, 2004

To: PROSPECTIVE BIDDERS AND ALL OTHERS CONCERNED

From: Betsy J. Cohen, CPPB, Contracts Supervisor

Subject: Bid-2009-04/BJC – Purchase of Lockable Sample Stations with Cyber Key Built-In.

Due Date: December 17, 2004

ADDENDUM NO.1

The information included in this addendum revises or supplements the specifications and other provisions of the contract documents and is considered part and parcel to the Bid Package.

Number of pages: 2 (including this page)

Failure to acknowledge receipt of this addendum on the bid form may result in disqualification of your bid submittal. Indicate acknowledgment of this Addendum in the Bid Form Page.

Signature on File

Betsy J. Cohen, CPPB
Purchasing Supervisor

Answers to questions received for Bid-2009-04/BJC:

Question #1:

The included drawing illustrates a 12-inch bury depth for the enclosure's base. Is the expectation that the connection is 3 feet below grade or does the housing need to extend that distance?

Answer:

The housing does not have to extend the complete bury depth. 12" is adequate.

Question #2:

If freeze protection is an issue, would Seminole County like to see a 'stop & drain with backflow prevention' included with the CyberLock Sample Stations?

Answer:

Freeze protection will not be an issue; therefore, Seminole County will not need drains on the sampling stations.

END OF ADDENDUM #1