



May 9, 2005

To: PROSPECTIVE BIDDERS AND ALL OTHERS CONCERNED

From: Diane Reed, Contracts Analyst

Subject: **BD-2119-05/DRR Fire Training Center Delivery Door**

Due Date: May 18, 2005 @ 2:00 PM

ADDENDUM #1

Total pages: 1

The information included in this Addendum revises, clarifies, or supplements the specifications and other provisions of the contract documents and is considered part and parcel to the Bid Package.

Question submitted by those attending the pre-bid:

1. Is anything to be done with the dock level inside the door? NO, it is not a part of this bid and it is staying there.

Statements:

Include a chain hoist with the price of the door.

The door is to be a sectional roll-up with no windows.

The current door opening is 10 ft X 12 ft instead of 12 ft X 12 ft as stated in the original scope.
The new door is to be 14 feet wide by 16 feet high.

The completion time for the project has been extended from Twenty-four (24) days to Forty-five (45) days from the execution of the Agreement.

The drawings of the building can be viewed by clicking "Tech Spec Images".

Failure to acknowledge receipt of this addendum on the submittal SHALL result in disqualification of your bid response.

Signature on File

Diane Reed, Contracts Analyst